

ANALYTICAL REPORT
HOUSEHOLD QUALITY

Platte Valley Labs
PO Box 807
914 Highway 30
Gibbon NE 68840

Date Received 5/12/2004
Date Reported 5/18/2004
Report Number 3513
Report Page 1 of 2

◆ Lab Number: 18009

◆ Analysis For: _____

◆ Sample ID: OFFICE

pH		7.6	<i>Acceptable</i>
Conductivity	mmhos/cm	0.47	
Total Alkalinity	ppm CaCO3	220	
Hardness	gr/gal	12.4	<i>Very Hard</i>
Calcium	ppm Ca	67	
Magnesium	ppm Mg	11	
Nitrate	ppm NO3-N	0.8	<i>Safe</i>
Coliform		Negative	<i>Safe</i>
Presence or Absence			
D.L. = Detection Limit			
Reviewed By: _____			

ANALYTICAL REPORT

HOUSEHOLD QUALITY

Platte Valley Labs
PO Box 807
914 Highway 30
Gibbon NE 68840

Date Received 5/12/2004
Date Reported 5/18/2004
Report Number 3513
Report Page 2 of 2

◆ Lab Number: 18010

◆ Analysis For: _____

◆ Sample ID: GIBBON

pH		7.6	<i>Acceptable</i>
Conductivity	mmhos/cm	2.35	
Total Alkalinity	ppm CaCO3	312	
Hardness	gr/gal	33.7	<i>Very Hard</i>
Calcium	ppm Ca	165	
Magnesium	ppm Mg	40	
Nitrate	ppm NO3-N	40	<i>*Unsafe*</i>
Coliform	Presence or Absence		
D.L. = Detection Limit			
Reviewed By: _____			